

BUREAU OF FIRE SERVICES ENGINEERING PLAN REVIEW

Legend



Is the project located in an Inpatient Health Care area (UH, CVC, MOTT or UH South), or is it a licensed freestanding surgical outpatient facility?

*Note: The title of the project on the BFS application must always read:

- UNIV MICH HLTH SYS-UNIVERSITY HOSPITAL
- UNIV MICH HLTH SYS-CARDIOVASCULAR CENTER
- UNIV MICH HLTH SYS-CHILDRENS HOSPITAL
- UNIV MICH HLTH SYS-UNIVERSITY HOSPITAL SOUTH

(Please note that the address on the form should always match the specific building's address)

Yes

No

Is the project 1:1 replacement of building components, OR routine maintenance, OR limited to modifications to non-rated walls and doors with no impact on means of egress, OR limited to hardware changes to an existing rated door?

Does the project modify (i.e., the THC sprinkler system) a fire suppression system shared with Inpatient Health Care area or with a licensed freestanding surgical outpatient facility and/or
Does the project include work to a fire alarm system shared with Inpatient Health Care area or with a licensed freestanding surgical outpatient facility?

No

Yes

Yes

No

Does the project impact the Fire alarm or Fire suppression system, or move/modify the rating of fire rated, or smoke barrier, or corridor, walls, doors, shafts or floor/ceiling assemblies, OR means of egress?

Does the scope of work include modifications to the Fire alarm or Fire suppression system other than routine maintenance? (1:1 replacement)

Yes

No

No

Yes

BFS Engineering Plan Review required *

BFS Engineering Plan Review NOT required

Fire alarm and/or suppression shop drawing submission IS required to as a stand-alone project. No architectural submission required.

Fire alarm and/or suppression shop drawing submission NOT required