



NOTES:

1. REFER TO U.L. FIRE STOPPING DETAIL #: C-AJ-8056 & C-AJ-0055 FOR FIRE STOPPING REQUIREMENTS.



2101 Commonwealth, Suite B
 Ann Arbor, MI 48105
 FAX: (734) 763-0417
www.med.umich.edu/facilities/plan

FILE: D260533H-FPD-4.dwg
 ISSUE: Aug 10

CONDUIT SLEEVE THRU FLOOR