



○ - TYPICAL DDC PANEL ASSEMBLY

0 NOT TO SCALE

**NOTES:**

1. PROVIDE (2) 20A DEDICATED ELECTRICAL CIRCUITS, ONE FOR THE UPS FEEDING THE CONTROLLERS IN THE DDC PANEL & ONE FOR DDC DEVICES IN THE AUXILIARY PANEL.
2. FOR PANEL INSTALLATIONS IN TELECOM OR ELECTRICAL ROOMS, FREE & CLEAR OF DUST & ABUSE, UPS CAN BE WALL MOUNTED EXPOSED INSTEAD OF WITHIN A VENTILATED PANEL ENCLOSURE.