



1. WHEN THE SYSTEM IS IN THE "SUMMER" MODE OF OPERATION AND WITH CHILLER #1, #2 OR #3 OPERATING, THE CONDENSER WATER VALVES V-10/V-11 WILL BE MODULATED AS REQUIRED TO MAINTAIN A CONDENSER WATER SUPPLY TEMPERATURE SETPOINT OF 85 DEG F (ADJUSTABLE) AT THE CONDENSER INLET OF CHILLER #1, #2 AND #3.

NOTES:

- 1.) RTD = EXISTING TEMP SENSOR
PS = EXISTING PRESSURE SWITCH
- 2.) ALL VALVES ARE EXISTING

SEE SHEET 11 & 12 FOR PANEL INPUT/OUTPUT SUMMARY

E					Honeywell 23938 RESEARCH DR., FARMINGTON HILLS, 48335-2671 UNIVERSITY OF MICHIGAN HOSPITALS CHW LOOP EAST MECHANICAL BUILDING CONDENSER WATER LOOP
D					
C					
B	AS BUILT	8/13/92	J.V.		
A	GENERAL REVISION	1/22/91	J.V.		
REVISIONS			DATE	APPD.	
ENGINEERED BY: VASSALLO		DRAWN BY: JAV		DATE: 9/8/90	
DWG. FILE NAME: 20062-27		APPROVED BY:		SHEET 27 OF 36	
				JOB NUMBER 919-20062	
				REV E	