



NOTES:

1. ALL DAMPERS MUST HAVE U.L. 555 LABEL.
2. PROVIDE MINIMUM 24"x24" ACCESS DOOR IN ALL DUCTS WHEN SIZE PERMITS. FOR SMALLER DUCTS, MAKE ACCESS DOOR 2" LESS THAN DUCT x 24" LONG.
3. DAMPERS SHALL BE TYPE "B" OR "C" WITH 24 GA. MIN. BLADES AND 18 GA. MIN. ENCLOSURE WITH DUCT COLLARS AND 20 GA. MIN. STEEL CHANNEL FRAMES.
4. CURB SHALL BE 4"x4" GALV. ANGLE, ANCHORED & SEALED TO CONCRETE FLOOR W/ WELDED MITERED CORNERS. AS AN ALTERNATE, PROVIDE 4" HIGH CONCRETE CURB AT DUCT PENETRATION.

-
FIRE DAMPER-FLOOR INSTALLATION DETAIL

 0 NOT TO SCALE