

**CONDUIT PENETRATION DETAIL
AT INTERIOR CONCRETE/ CMU WALL**

 0 NOT TO SCALE

NOTES:

1. REFER TO U.L. FIRE STOPPING DETAIL #: C-AJ-1149 & C-AJ-1150 FOR FIRE STOPPING REQUIREMENTS.