



## NOTE:

- ALL LAVATORY/SINK ADA AND SHOWER MIXING VALVES SHALL BE PROVIDED WITH EXTERNAL BRONZE BODY & TRIM CHECK VALVES ON THE INCOMING HOT & COLD PIPING, REGARDLESS IF MIXING VALVE HAS INHERENT CHECK VALVES.
- AS AN ALTERNATE TO THE ABOVE, PROVIDE BRONZE BODY & TRIM CHECK VALVES ON THE HOT AND COLD WATER BRANCHES FEEDING A BATHROOM GROUP. LOCATE CHECK VALVES IN AN ACCESSIBLE LOCATION IMMEDIATELY DOWNSTREAM OF HW & CW SHUTOFF VALVES IN BRANCH PIPING.



2101 Commonwealth, Suite B Ann Arbor, MI 48105 FAX: (734) 763-0417

www.med.umich.edu/facilities/plan

FILE: D220010H-1.dwg ISSUE: Apr 16