



NOTES:

- 1. TERMINATE DRAIN AND VENT LINES WITHIN FUNNEL, MIN. 2x PIPE DIAMETER ABOVE FLOOR DRAIN.
- PREFERENCE IS TO UTILIZE FLOOR DRAIN. WHERE IMPRACTICAL OR COST PROHIBITIVE DUE TO EXISTING CONDITIONS, AN ABOVE GROUND INDIRECT WASTE RECEPTOR SHALL BE UTILIZED. COUNTERTOP SINKS SHALL NOT BE USED FOR DISCHARGING ICE MAKER DRAIN LINE.
- 3. PROVIDE UNIONS AND ROUTE DRAIN LINE TO ALLOW FOR DISASSEMBLY AND CLEANING.



2101 Commonwealth, Suite B Ann Arbor, MI 48105 FAX: (734) 763-0417

www.med.umich.edu/facilities/plan

FILE: D220010H-2.dwg ISSUE: March 2019