



PIPE SLEEVE THRU INTERIOR WALL
SCALE: NONE

NOTE:

1. ALL PIPE PENETRATIONS THRU FIRE RATED ASSEMBLIES SHALL BE SEALED IN ACCORDANCE WITH AN APPROVED UL LISTED INSTALLATION.