

# Medical Gas Alarm Panel

Zone valve box controls the indicated gases for the rooms listed below:

Room Name	Room #	Oxygen	Medical Air	Medical Vacuum	WAGD	Nitrous Oxide	Carbon Dioxide	Nitrogen 100 PSI

Last Updated: MM/YYYY

Contact Respiratory Care, pager 1550 (UH/CVC/CC/MED INN/THC/PAVILION (CIT))  
or pager 2569 (CW) and Hospital Maintenance (936-5054)  
for any questions and/or concerns.

Asset managed by Michigan Medicine Plumbing Shop.

**KEEP AREA IN FRONT OF THIS ALARM PANEL  
FREE OF OBSTRUCTIONS  
-PANEL MUST BE VIEWABLE AT ALL TIMES**

**DETAIL NOTES:**

1. PROVIDE 8-1/2x11 FULL VIEW HOLDER WITH PRINTABLE 8-1/2x11 PAPER INSERT WITH THE DETAIL ABOVE. CONTRACTOR TO COORDINATE PRODUCTION OF SIGNAGE WITH UM SIGN SHOP OR APPROVED VENDOR.
2. FONT AND TEXT SIZE TO BE THE FOLLOWING: TITLE TEXT, ARIAL 3/8", ALL OTHER TEXT TO BE ARIAL 3/16"

**NOTES TO EDITOR:**

1. COMPLETE TABLE WITH ROOM INFORMATION AND AN "X" IN THE RESPECTIVE MEDICAL GAS COLUMNS INDICATING GASES AVAILABLE.
2. LIST DATE OF SIGN POSTING UNDER "LAST UPDATED" (MONTH/YEAR)
3. EDIT RELEVANT RESPIRATORY CARE INFO BASED ON FACILITY WHERE SIGN IS INSTALLED. FOR FACILITIES NOT LISTED, DELETE REFERENCE TO RESPIRATORY CARE (I.E. "CONTACT HOSPITAL MAINTENANCE, 936-5054 FOR ANY QUESTIONS AND/OR CONCERNS.")
4. A/E TO INCLUDE SCHEDULE OF ALL ALARM PANEL SIGNS RELEVANT TO PROJECT SCOPE ON PROJECT CD'S.



2101 Commonwealth, Suite B  
Ann Arbor, MI 48105  
FAX: (734) 763-0417  
[www.med.umich.edu/facilities/plan](http://www.med.umich.edu/facilities/plan)  
FILE: D226000H-3.dwg  
ISSUE: May 18

**STANDARD MEDICAL  
GAS ALARM PANEL SIGN**