



## NOTES:

- 1. PROVIDE (2) 20A DEDICATED ELECTRICAL CIRCUITS, ONE FOR THE UPS FEEDING THE CONTROLLERS IN THE DDC PANEL & ONE FOR DDC DEVICES IN THE AUXILIARY PANEL.
- 2. FOR PANEL INSTALLATIONS IN TELECOM OR ELECTRICAL ROOMS, FREE & CLEAR OF DUST & ABUSE, UPS CAN BE WALL MOUNTED EXPOSED INSTEAD OF WITHIN A VENTILATED PANEL ENCLOSURE.



2101 Commonwealth, Suite B Ann Arbor, MI 48105 FAX: (734) 763-0417

www.med.umich.edu/facilities/plan

FILE: D230905H-11.dwg ISSUE: Aug 2016