



- NOTES:
1. FLEX DUCT IS NOT ALLOWED UPSTREAM OR DOWNSTREAM OF TERMINAL BOXES, EXCEPT IN THE BRANCH CONNECTION DIRECTLY TO DIFFUSER/GRILLES.
 2. TERMINAL BOX CONSTRUCTION THAT INCORPORATES A FACTORY PROVIDED ACCESS DOOR IN THE SIDE OF THE BOX CASING ARE ALLOWED TO MOUNT THE REHEAT COIL DIRECTLY TO THE TERMINAL BOX DISCHARGE OPENING AND FOREGO THE SHEET METAL EXTENSION BETWEEN BOX & COIL.
 3. TERMINAL BOXES SHALL BE MOUNTED NO HIGHER THAN 2' ABOVE THE CEILING GRID & SHALL BE LOCATED SO AS TO ALLOW CLEAR VERTICAL LADDER ACCESS FOR MAINTENANCE.

**TYPICAL TERMINAL BOX
INSTALLATION DETAIL**

SCALE: NONE

